

APPENDIX K

TRANSITION PLAN

3-YEAR TRANSITION PLAN

PRIORITY 1 – APPROACH & ENTRANCE

Area	Access Issue	Solution	Target Date	Person Responsible	Est. Cost
Armory Annex	Additional accessible parking space needs to be added.	Configure additional accessible parking space at Health Department entrance.	By year-end 2022	Maintenance Staff	\$200
Armory Annex	Door closer at West Entrance closes too fast.	Adjust closer to be compliant.	By year-end 2022	Maintenance Staff	\$100
South Annex	Building needs evaluated.	Evaluate building using ADA Checklist for Existing Facilities.	By year-end 2023	ADA Coordinator & Maintenance Supervisor	\$0
Eagles Bluff	Van accessible space needs configured and accessible parking spaces need repainted.	Add van accessible sign and re-paint lines.	By year-end 2023	Parks and Recreation/Maintenance Staff	\$200
Eagles Bluff	Edges of carpet/mats are not compliant.	Assess and correct to make compliant.	By year-end 2023	Parks and Recreation /Maintenance Staff	\$100
Multi Services Building	Accessible parking space is not configured properly.	Configure accessible parking space that adjoins accessible route to entrance of building.	By year-end 2024	Maintenance Staff & Highway Superintendent	\$200
Multi Services Building	Edges of carpet/mats not compliant.	Assess and correct to make compliant.	By year-end 2024	Maintenance Staff & Highway Superintendent	\$100
Wilkerson Park	There is no accessible parking space.	Configure accessible parking space.	By year-end 2024	Parks and Recreation /Maintenance Staff	TBD
Wilkerson Park	There is no accessible route to restroom and shelter.	Construct accessible route to restroom and shelter from accessible parking space.	By year-end 2024	Parks and Recreation /Maintenance Staff	TBD
Voting Locations	No record of polling place evaluations on file.	Evaluate polling places.	By year-end 2024	ADA Coordinator & Clerk	TBD

PRIORITY 2 – ACCESS TO GOODS AND SERVICES

Area	Access Issue	Solution	Target Date	Person Responsible	Est. Cost
Courthouse	Door closers throughout facility need adjusted.	Assess all interior door closers and make necessary adjustments to ensure compliance.	By year-end 2022	Maintenance Supervisor	\$100
Courthouse	Operable parts need to be compliant.	Assess all operable parts and make necessary adjustments to ensure compliance.	By year-end 2022	Maintenance Supervisor	\$100
Multi Services Building	Door hardware to radio communications room is not compliant.	Replace with compliant door hardware.	By year-end 2023	Maintenance Supervisor & Highway Superintendent	\$100
Prosecutor's Office	Accessible route should be a minimum of 36 inches wide.	Assess to identify areas and make necessary adjustments or recommendations to building owner.	By year-end 2024	ADA Coordinator	\$0
Prosecutor's Office	Fire extinguisher protrusion is more than 4".	Assess to identify area and make necessary adjustments or recommendations to building owner.	By year-end 2024	ADA Coordinator	\$0
Prosecutor's Office	No tactile signs	Assess areas and notify building owner of any proposed changes.	By year-end 2024	ADA Coordinator	\$200